

Approved : Yes

Date Issued: 23/07/2004
Issue No: 1

311712003039

Build Specification:

Body	304104	3/4" x 3/4"
Inlet / Outlet Connections	None	K30
Orifice Size	304095	3.4 x 4.0mm
Main Spring	304081	Natural
Relief Spring and Setting	10417S Short	4.5 - 5"wc
Cap	304074	Green
Adjuster Screw	304073	Green
Filter Housing	304113	No Test Point
Colour	Powder Coat Y65 Mushroom	Filter
Lever / Vent	304052	304025
Deflector	Yes	Screw Type
		Yes
		Yes
		Molybond

Performance Requirements:


Minimum / Maximum Inlet Pressure (kPa)	45	450
Nominal Outlet Pressure (kPa)	2.5 kPa	
Set Point Flow Rate (m3/hr) / Inlet Pressure (kPa)	1.2	Set at 200
Capacity Req'd (m3/hr) @ Min Inlet With 20% Droop	10	Gas (SG0.60)
Relief @ Maximum Inlet Pressure	Less than 7 kPa	

Special Notes / Requirements:

Product Photo



Label Location : Reg Neck



NOTE: A WARNING LABEL IS ATTACHED TO ALL REGULATORS

THIS IS AN UNCONTROLLED DOCUMENT